



# **Georgia State Amendments to the International Plumbing Code (2006 Edition)**



Georgia Department of Community Affairs  
Planning and Environmental Management Division  
60 Executive Park South, N.E.  
Atlanta, Georgia 30329-2231  
(404) 679-3118  
[www.dca.state.ga.us](http://www.dca.state.ga.us)

**Revised January 1, 2008**

**GEORGIA STATE MINIMUM STANDARD PLUMBING CODE  
(INTERNATIONAL PLUMBING CODE WITH GEORGIA STATE AMENDMENTS)**

**The INTERNATIONAL PLUMBING CODE, 2006 Edition, published by the International Code Council, when used in conjunction with these Georgia State Amendments and the Georgia State Amendments adopted effective January 1 of 2007, shall constitute the official *Georgia State Minimum Standard Plumbing Code*.**

**GEORGIA STATE AMENDMENTS**

**CODE REFERENCE:**

- (a) Replace all references to the ICC *Electrical Code* with references to the *Georgia State Minimum Standard Electrical Code (National Electrical Code with Georgia State Amendments)*.
- (b) Replace all references to the *International Energy Conservation Code (IECC)* with references to the *Georgia State Minimum Standard Energy Code (IECC with Georgia State Supplements and Amendments)*. The *Georgia State Minimum Standard Energy Code* shall be used for efficiency and coefficient of performance ratings of plumbing equipment.

**GEORGIA STATE MINIMUM  
REQUIREMENTS FOR BOILERS/WATER HEATERS AND PRESSURE VESSELS**

The State's minimum requirements for boilers/water heaters and pressure vessels over 200,000 BTU/h (58.61 kW), 210 degrees Fahrenheit or 120 gallons capacity shall be established by O.C.G.A. Title 34, Chapter 11 and the Rules and Regulations of the Georgia Department of Labor.

*\*Revise the International Plumbing Code, 2006 Edition, as follows:*

**CHAPTER 10  
TRAPS, INTERCEPTORS AND SEPARATORS**

**SECTION 1003  
INTERCEPTORS AND SEPARATORS**

\*Add exception to Section 1003.4 'Oil separators required' of the Georgia Amendment revised January 1, 2007 to read as follows:

**1003.4 Oil separators required.**

**Exception:**

In elevator pits where oil containment complies with the Georgia Department of Labor Elevator Rules and Regulations, no additional oil separator shall be required. At repair garages, car-washing facilities, and factories where oily and flammable liquid wastes are produced, separators shall be installed into which all oil-bearing, grease-bearing or flammable wastes shall be discharged before emptying into the building drainage system or other point of disposal.

(Effective January 1, 2008)

**End of Amendments.**