

CECD1-15-22

IECC: CD101.1, CD101.2

Proponents: Greg Eades, representing IECC Modeling, Whole Building Metrics, Zero Energy Subcommittee

2024 International Energy Conservation Code [CE Project]

Revise as follows:

CD101.1 Prescriptive compliance. Where compliance is demonstrated using the prescriptive compliance option in Section C401.2.1, the number of additional efficiency credits required by Section C406.1 shall be ~~50 percent higher than~~ 1.43 times the number that required by Table C406.1.1.

CD101.2 Total building performance compliance . Where compliance is demonstrated using the total building performance option of Section C401.2.1, the percentage of annual energy cost (PAEC), applied to the standard reference design referenced in Equation 4-23, shall be multiplied by ~~0.98~~ 0.97.

Reason: The Glide Path appendix was originally approved with "placeholder" values, pending evaluation of the overall code progress. Attached please find the proposed revisions to those values, based on input from PNNL and Mike Waite.

Cost Impact: The code change proposal will neither increase nor decrease the cost of construction.
this modifications do not increase or decrease the cost of construction