

## **CECD1-6-22**

**IECC: TABLE C406.2(1), TABLE 406.2(2), TABLE 406.2(3), TABLE 406.2(5), TABLE 406.2(9), C406.2.5.4, TABLE C406.2.5.4**

**Proponents:** Michael Jouaneh, representing IECC CE Electrical Power, Lighting, and Renewables Subcommittee  
(iecccelectrical@iccsafe.org)

### **2024 International Energy Conservation Code [RE Project]**

**Revise as follows:**

**TABLE C406.2(1) BASE ENERGY CREDITS FOR GROUP R-2, R-4, AND I-1 OCCUPANCIES<sup>a</sup>**

ID	Energy Credit Measure	Section	Climate Zone																		
			0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
E01	Envelope Performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																		
E02	UA reduction (15%)	C406.2.1.2	8	13	7	11	6	8	9	6	1	24	8	9	30	15	5	32	28	31	36
E03	Envelope leak reduction	C406.2.1.3	15	10	12	8	6	16	13	5	1	7	7	9	65	16	1	73	43	52	26
E04	Add Roof Insulation	C406.2.1.4	1	1	1	1	1	1	4	3	1	5	3	4	6	5	1	7	7	6	8
E05	Add Wall Insulation	C406.2.1.5	10	10	6	8	5	6	8	4	1	8	3	4	11	7	1	14	12	13	13
E06	Improve Fenestration	C406.2.1.6	7	7	4	6	9	11	13	3	1	22	5	10	27	18	7	41	33	22	21
H01	HVAC Performance	C406.2.2.1	20	19	16	17	14	13	11	11	5	13	10	8	15	12	7	18	14	17	19
H02	Heating efficiency	C406.2.2.2	x	x	x	x	x	x	3	1	1	6	2	3	10	5	2	14	10	13	16
H03	Cooling efficiency	C406.2.2.3	7	6	4	4	3	3	1	1	1	1	1	1	1	1	x	x	x	x	x
H04	Residential HVAC control	C406.2.2.4	9	10	8	22	20	25	16	17	32	21	24	17	23	27	16	21	24	18	18
H05	DOAS/fan control	C406.2.2.5	32	31	27	28	23	23	28	21	12	42	24	24	56	36	19	73	54	70	79
W01	SHW preheat recovery	C406.2.3.1 a	61	63	74	74	85	88	101	100	121	103	109	122	102	111	130	93	106	99	96
W02	Heat pump water heater	C406.2.3.1 b	50	52	62	61	72	74	86	85	104	88	94	106	88	96	112	81	92	87	84
W03	Efficient gas water heater	C406.2.3.1 c	38	39	46	46	53	55	63	62	76	64	68	76	64	69	81	58	66	62	60
W04	SHW pipe insulation	C406.2.3.2	7	7	8	7	8	8	8	9	10	8	9	9	7	8	9	6	7	6	6
W05	Point of use water heaters	C406.2.3.3 a	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W06	Thermostatic bal. valves	C406.2.3.3 b	3	3	3	3	3	3	3	3	4	3	3	4	3	3	4	3	3	3	2
W07	SHW heat trace system	C406.2.3.3 c	12	12	13	13	14	15	15	15	18	14	15	16	13	14	16	11	13	11	10
W08	SHW submeters	C406.2.3.4	11	11	13	13	15	16	18	18	22	19	20	22	19	20	24	17	20	18	18
W09	SHW distribution sizing	C406.2.3.5	45	46	55	54	63	65	74	73	89	75	80	89	74	81	95	68	77	72	70
W10	Shower heat recovery	C406.2.3.6	15	16	19	19	22	23	26	26	32	27	29	32	27	29	34	25	28	27	26
P01	Energy monitoring	C406.2.4	3	3	2	3	2	2	2	2	2	2	2	2	2	2	2	3	2	2	3
L01	Lighting Performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L02	Lighting dimming & tuning	C406.2.5.2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
L03	Increase occp. sensor	C406.2.5.3	3	3	4	4	4	4	3	4	3	2	3	2	1	1	2	1	1	1	1
L04	Increase daylight area	C406.2.5.4	<del>5</del>	<del>5</del>	<del>5</del>	<del>5</del>	<del>5</del>	<del>5</del>	<del>4</del>	<del>4</del>	<del>4</del>	<del>4</del>	<del>4</del>	<del>3</del>	<del>3</del>	<del>4</del>	<del>3</del>	<del>2</del>	<del>3</del>	<del>2</del>	
L05	Residential light control	C406.2.5.5	8	8	9	9	9	9	8	8	10	6	8	7	4	6	8	3	5	4	3
L06	Light power reduction	C406.2.5.7	2	2	2	2	2	2	2	2	2	1	2	1	1	1	1	1	1	1	1
Q01	Efficient elevator	C406.2.6.1	4	4	4	4	5	5	5	5	5	4	5	5	4	4	5	4	4	4	3
Q02	Commercial kitchen equip.	C406.2.6.2	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q03	Residential kitchen equip.	C406.2.6.3	15	15	17	16	17	18	17	18	20	16	17	18	15	16	18	13	15	13	12
Q04	Fault detection	C406.2.6.4	3	3	2	3	2	2	2	2	1	2	2	1	1	2	1	3	2	3	3

a. "x" indicates credit is not available for that measure.

**TABLE 406.2(2) BASE ENERGY CREDITS FOR GROUP I-2 OCCUPANCIES<sup>a</sup>**

ID	Energy Credit Measure	Section	Climate Zone																		
			0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
E01	Envelope Performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																		
E02	UA reduction (15%)	C406.2.1.2	6	11	6	11	7	9	6	6	2	3	3	3	4	3	7	5	5	17	3
E03	Envelope leak reduction	C406.2.1.3	5	3	4	3	5	8	8	3	2	6	2	2	7	3	1	9	7	19	5
E04	Add Roof Insulation	C406.2.1.4	1	1	1	1	1	1	1	1	1	1	1	1	2	1	1	2	1	2	3
E05	Add Wall Insulation	C406.2.1.5	1	3	1	3	2	2	9	4	1	4	1	1	3	1	1	3	3	3	3
E06	Improve Fenestration	C406.2.1.6	1	1	1	1	1	1	1	1	1	4	3	5	5	1	1	5	5	2	2
H01	HVAC Performance	C406.2.2.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
H02	Heating efficiency	C406.2.2.2	x	x	x	x	2	3	4	3	7	6	4	6	8	6	10	11	12	15	19
H03	Cooling efficiency	C406.2.2.3	6	6	4	4	3	3	2	2	1	1	1	1	1	1	x	x	x	x	
H04	Residential HVAC control	C406.2.2.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
H05	DOAS/fan control	C406.2.2.5	41	41	40	40	42	36	42	37	39	49	40	46	56	46	61	65	68	82	93
W01	SHW preheat recovery	C406.2.3.1 a	4	4	4	4	5	5	5	5	6	6	6	6	6	6	6	5	5	5	
W02	Heat pump water heater	C406.2.3.1 b	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	3
W03	Efficient gas water heater	C406.2.3.1 c	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	3	3
W04	SHW pipe insulation	C406.2.3.2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
W05	Point of use water heaters	C406.2.3.3 a	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
W07	SHW heat trace system	C406.2.3.3 c	1	1	2	2	2	2	2	2	2	2	2	2	2	2	1	1	1	1	1
W08	SHW submeters	C406.2.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W09	SHW flow reduction	C406.2.3.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W10	Shower heat recovery	C406.2.3.6	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
P01	Energy monitoring	C406.2.4	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
L01	Lighting Performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L02	Lighting dimming & tuning	C406.2.5.2	5	5	5	5	5	6	5	6	6	5	6	6	5	5	5	4	4	3	2
L03	Increase occp. sensor	C406.2.5.3	5	5	5	5	5	5	5	5	6	5	5	6	5	5	5	4	4	3	2
L04	Increase daylight area	C406.2.5.4	<del>7</del> <sub>x</sub>	<del>7</del> <sub>x</sub>	<del>7</del> <sub>x</sub>	<del>7</del> <sub>x</sub>	<del>7</del> <sub>x</sub>	<del>7</del> <sub>x</sub>	<del>7</del> <sub>x</sub>	<del>7</del> <sub>x</sub>	<del>8</del> <sub>x</sub>	<del>6</del> <sub>x</sub>	<del>6</del> <sub>x</sub>	<del>6</del> <sub>x</sub>	<del>6</del> <sub>x</sub>	<del>5</del> <sub>x</sub>	<del>5</del> <sub>x</sub>	<del>5</del> <sub>x</sub>	<del>5</del> <sub>x</sub>	<del>4</del> <sub>x</sub>	
L05	Residential light control	C406.2.5.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L06	Light power reduction	C406.2.5.7	7	7	7	7	7	7	7	7	9	7	7	8	6	7	7	5	5	4	3
Q01	Efficient elevator	C406.2.6.1	1	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	1	1	1
Q02	Commercial kitchen equip.	C406.2.6.2	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q03	Residential kitchen equip.	C406.2.6.3	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q04	Fault detection	C406.2.6.4	3	3	3	3	3	3	3	3	2	3	3	2	3	3	3	3	3	4	4

a. "x" indicates credit is not available for that measure.

**TABLE 406.2(3) BASE ENERGY CREDITS FOR GROUP R-1 OCCUPANCIES<sup>a</sup>**

ID	Energy Credit Measure	Section	Climate Zone																		
			0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
E01	Envelope Performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																		
E02	UA reduction (15%)	C406.2.1.2	4	7	4	7	3	4	7	2	1	7	2	3	10	6	4	12	9	19	11
E03	Envelope leakage reduction	C406.2.1.3	5	3	4	2	2	2	5	1	1	8	1	2	13	4	1	18	9	18	7
E04	Add Roof Insulation	C406.2.1.4	2	2	2	2	2	2	3	2	1	3	1	2	3	2	2	3	3	2	3
E05	Add Wall Insulation	C406.2.1.5	13	14	8	11	4	4	7	4	1	5	2	4	6	4	3	9	7	10	8
E06	Improve Fenestration	C406.2.1.6	5	5	4	5	7	7	8	2	1	8	2	4	10	5	1	21	17	10	9
H01	HVAC Performance	C406.2.2.1	21	20	17	18	16	13	12	12	11	11	11	8	11	11	8	13	11	14	16
H02	Heating efficiency	C406.2.2.2	x	x	x	x	x	x	1	1	6	2	1	1	3	2	2	6	4	8	11
H03	Cooling efficiency	C406.2.2.3	7	6	4	4	3	2	1	2	1	1	2	1	1	1	1	x	x	x	x
H04	Residential HVAC control	C406.2.2.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
H05	DOAS/fan control	C406.2.2.5	32	30	26	28	25	23	24	22	28	26	22	20	30	26	19	41	34	48	62
W01	SHW preheat recovery	C406.2.3.1 a	18	19	22	22	25	27	31	21	32	34	34	38	37	36	40	36	37	36	35
W02	Heat pump water heater	C406.2.3.1 b	14	15	18	17	20	22	25	25	27	29	29	32	31	31	34	30	32	31	30
W03	Efficient gas water heater	C406.2.3.1 c	11	12	14	14	16	17	19	19	20	21	21	24	23	23	25	22	23	23	22
W04	SHW pipe insulation	C406.2.3.2	3	3	4	3	4	4	4	4	4	4	4	4	4	4	4	4	4	4	3
W05	Point of use water heaters	C406.2.3.3 a	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	2	2	2	2	2	2	2	2	2	2	2	2	1	1
W07	SHW heat trace system	C406.2.3.3 c	5	6	6	6	6	7	7	7	7	7	7	8	7	7	8	7	7	6	6
W08	SHW submeters	C406.2.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W09	SHW flow reduction	C406.2.3.5	13	14	16	16	18	20	22	22	23	25	25	28	27	26	29	26	27	26	25
W10	Shower heat recovery	C406.2.3.6	4	5	5	5	6	7	8	8	8	9	9	10	10	9	10	9	10	10	9
P01	Energy monitoring	C406.2.4	3	3	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
L01	Lighting Performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L02	Lighting dimming & tuning	C406.2.5.2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
L03	Increase occp. sensor	C406.2.5.3	3	3	3	3	3	3	3	3	3	4	2	3	2	2	3	2	2	1	1
L04	Increase daylight area	C406.2.5.4	<del>4</del> <sub>x</sub>	<del>5</del> <sub>x</sub>	<del>5</del> <sub>x</sub>	<del>4</del> <sub>x</sub>	<del>5</del> <sub>x</sub>	<del>5</del> <sub>x</sub>	<del>4</del> <sub>x</sub>	<del>4</del> <sub>x</sub>	<del>4</del> <sub>x</sub>	<del>5</del> <sub>x</sub>	<del>4</del> <sub>x</sub>	<del>4</del> <sub>x</sub>	<del>3</del> <sub>x</sub>	<del>4</del> <sub>x</sub>	<del>3</del> <sub>x</sub>	<del>3</del> <sub>x</sub>	<del>3</del> <sub>x</sub>	<del>2</del> <sub>x</sub>	
L05	Residential light control	C406.2.5.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L06	Light power reduction	C406.2.5.7	1	1	2	2	2	2	2	2	2	2	1	2	1	1	2	1	1	1	1
Q01	Efficient elevator	C406.2.6.1	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	2	2	2	2
Q02	Commercial kitchen equip.	C406.2.6.2	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q03	Residential kitchen equip.	C406.2.6.3	9	9	10	10	10	11	11	11	11	11	11	12	11	11	12	10	11	10	9
Q04	Fault detection	C406.2.6.4	3	3	3	3	2	2	2	2	2	2	2	2	2	2	1	2	2	2	2

a. "x" indicates credit is not available for that measure.

**TABLE 406.2(5) BASE ENERGY CREDITS FOR GROUP A-2 OCCUPANCIES<sup>a</sup>**

ID	Energy Credit Measure	Section	Climate Zone																		
			0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
E01	Envelope Performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																		
E02	UA reduction (15%)	C406.2.1.2	1	1	1	1	2	2	9	2	1	19	4	5	26	7	3	33	23	29	13
E03	Envelope leak reduction	C406.2.1.3	2	1	1	1	2	3	11	2	1	24	4	6	33	9	3	42	29	36	16
E04	Add Roof Insulation	C406.2.1.4	1	1	0	1	1	1	2	1	1	1	1	1	2	2	1	2	2	1	2
E05	Add Wall Insulation	C406.2.1.5	1	1	0	1	1	2	3	3	1	2	1	1	2	2	2	2	2	2	2
E06	Improve Fenestration	C406.2.1.6	1	1	1	1	1	1	2	2	1	1	2	2	3	2	1	4	4	1	1
H01	HVAC Performance	C406.2.2.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
H02	Heating efficiency	C406.2.2.2	x	x	x	x	1	1	6	3	3	10	6	8	15	11	10	19	15	23	28
H03	Cooling efficiency	C406.2.2.3	6	5	3	4	3	2	1	1	1	1	1	1	1	1	x	x	x	x	
H04	Residential HVAC control	C406.2.2.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
H05	DOAS/fan control	C406.2.2.5	29	27	20	25	24	21	36	27	15	51	35	38	67	53	45	84	70	97	115
W01	SHW preheat recovery	C406.2.3.1 a	24	26	31	29	33	35	37	38	45	38	41	44	37	40	44	34	38	33	30
W02	Heat pump water heater	C406.2.3.1 b	15	16	19	18	21	23	25	25	29	26	28	30	26	28	31	25	27	24	22
W03	Efficient gas water heater	C406.2.3.1 c	15	16	19	18	21	22	23	24	28	24	25	27	23	25	27	21	24	21	18
W04	SHW pipe insulation	C406.2.3.2	2	3	3	3	3	3	3	3	3	3	3	3	2	3	3	2	2	2	2
W05	Point of use water heaters	C406.2.3.3 a	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
W07	SHW heat trace system	C406.2.3.3 c	3	4	4	4	4	4	4	4	4	4	4	4	3	4	4	3	3	3	3
W08	SHW submeters	C406.2.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W09	SHW flow reduction	C406.2.3.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W10	Shower heat recovery	C406.2.3.6	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
P01	Energy monitoring	C406.2.4	2	2	2	2	2	1	2	1	1	2	1	1	2	2	1	2	2	2	3
L01	Lighting Performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L02	Lighting dimming & tuning	C406.2.5.2	2	2	2	2	2	2	2	2	2	2	2	2	1	2	1	1	1	1	0
L03	Increase occp. sensor	C406.2.5.3	2	2	2	2	2	2	2	2	2	1	1	1	1	1	1	1	1	1	0
L04	Increase daylight area	C406.2.5.4	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	<del>3</del>	
L05	Residential light control	C406.2.5.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L06	Light power reduction	C406.2.5.7	3	3	3	3	3	3	3	3	3	2	2	2	2	2	2	1	2	1	1
Q01	Efficient elevator	C406.2.6.1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Q02	Commercial kitchen equip.	C406.2.6.2	24	26	28	27	28	29	27	29	32	26	28	29	24	26	28	21	23	19	17
Q03	Residential kitchen equip.	C406.2.6.3	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q04	Fault detection	C406.2.6.4	3	2	2	2	2	2	2	2	1	2	2	1	2	2	2	3	2	3	4

a. "x" indicates measure is not available for that measure.

**TABLE 406.2(9) BASE ENERGY CREDITS FOR OTHER OCCUPANCIES<sup>a,b</sup>**

ID	Energy Credit Measure	Section	Climate Zone																		
			0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
E01	Envelope Performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																		
E02	UA reduction (15%)	C406.2.1.2	5	9	5	8	5	6	10	5	2	20	6	6	25	10	4	28	22	26	16
E03	Envelope leak reduction	C406.2.1.3	6	4	5	4	3	7	12	3	2	28	5	6	36	9	3	41	27	33	15
E04	Add Roof Insulation	C406.2.1.4	4	4	3	4	4	4	8	6	2	7	6	7	9	8	9	9	10	9	12
E05	Add Wall Insulation	C406.2.1.5	16	19	11	17	5	6	10	7	2	9	6	8	9	7	7	9	9	10	8
E06	Improve Fenestration	C406.2.1.6	4	4	3	4	5	6	6	4	1	9	4	7	11	7	6	16	14	8	8
H01	HVAC Performance	C406.2.2.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
H02	Heating efficiency	C406.2.2.2	x	x	x	x	x	x	6	2	3	11	6	8	15	11	9	18	15	19	23
H03	Cooling efficiency	C406.2.2.3	7	7	5	5	4	3	1	2	1	x	x	x	x	x	x	x	x	x	x
H04	Residential HVAC control	C406.2.2.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
H05	DOAS/fan control	C406.2.2.5	7	36	31	34	30	28	43	32	23	61	42	49	75	61	49	90	77	93	90
W01	SHW preheat recovery	C406.2.3.1 a	18	19	22	21	25	26	28	29	34	29	31	34	29	31	35	26	29	27	26
W02	Heat pump water heater	C406.2.3.1 b	12	12	15	14	17	17	20	20	24	21	22	25	21	23	26	20	22	21	20
W03	Efficient gas water heater	C406.2.3.1 c	11	11	13	13	15	16	17	17	21	18	19	21	18	19	22	16	18	17	16
W04	SHW pipe insulation	C406.2.3.2	3	3	4	4	4	4	4	4	5	4	4	5	4	4	5	3	4	3	3
W05	Point of use water heaters	C406.2.3.3 a	8	10	11	10	11	12	12	12	14	13	13	14	13	13	14	11	12	12	11
W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	1	1	1	2	1	1	2	1	1	2	1	1	1	1
W07	SHW heat trace system	C406.2.3.3 c	5	5	5	5	6	6	6	6	7	6	6	7	5	6	7	5	5	5	5
W08	SHW submeters	C406.2.3.4	11	11	13	13	15	16	18	18	22	19	20	22	19	20	24	17	20	18	18
W09	SHW flow reduction	C406.2.3.5	29	30	36	35	41	43	48	48	56	50	53	59	51	54	62	47	52	49	48
W10	Shower heat recovery	C406.2.3.6	6	6	7	7	8	9	10	10	11	10	11	12	10	11	12	10	11	10	10
P01	Energy monitoring	C406.2.4	4	4	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	4
L01	Lighting Performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L02	Lighting dimming & tuning	C406.2.5.2	5	5	5	5	6	6	5	6	7	5	5	5	4	4	5	3	4	3	2
L03	Increase occp. sensor	C406.2.5.3	5	6	6	6	7	7	6	7	8	5	6	6	4	5	6	3	4	3	2
L04	Increase daylight area	C406.2.5.4	<del>7</del>	<del>8</del>	<del>9</del>	<del>8</del>	<del>9</del>	<del>9</del>	<del>8</del>	<del>8</del>	<del>10</del>	<del>6</del>	<del>7</del>	<del>7</del>	<del>5</del>	<del>6</del>	<del>6</del>	<del>4</del>	<del>5</del>	<del>5</del>	<del>4</del>
L05	Residential light control	C406.2.5.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L06	Light power reduction	C406.2.5.7	7	7	8	7	8	8	7	8	9	5	7	6	4	5	6	4	4	3	2
Q01	Efficient elevator	C406.2.6.1	4	4	5	4	5	5	5	5	6	4	5	5	4	4	5	3	4	3	3
Q02	Commercial kitchen equip.	C406.2.6.2	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q03	Residential kitchen equip.	C406.2.6.3	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q04	Fault detection	C406.2.6.4	3	3	3	3	3	2	3	2	2	3	3	2	3	3	2	4	3	4	4

a. "x" indicates measure is not available for that measure.

b. Other occupancy groups include all Groups except for Groups A-2, B, E, I, M, and R.

**C406.2.5.4 L04 Increase daylight area.** The total daylight area of the building project (DLA<sub>BLDG</sub>) ~~with continuous daylight dimming meeting the requirements of C405.2.4~~ determined by Equation 4-23 shall be at least 5 percent greater than the typical ~~daylit~~ daylight area (DLA<sub>Typ</sub>) from Table C406.2.5.4.

$$DLA_{BLDG} = DLZ / LFA$$

(Equation 4-23)

where:

DLZ = The total building floor area located within sidelit and toplit daylight zones complying with C405.2.4.2 or C405.2.4.3 and provided with daylight responsive controls complying with C405.2.4.1. ft<sup>2</sup> or m<sup>2</sup>.

LFA = The total building floor area used to determine the lighting power allowance in C405.3.2. ft<sup>2</sup> or m<sup>2</sup>.

Credits for measure L04 shall be determined by ~~based on~~ Equation 4-24 or Equation 4-25, whichever is less::

(Equation 4-24)

$$EC_{DL} = EC_{DL5} \times 20 \times (DLA_{BLDG} - DLA_{TYP})$$

$EC_{DL}$  = The lesser of actual area of *daylight zones* in the *building* with continuous daylight dimming, ft<sup>2</sup> or m<sup>2</sup> and (GLFA x  $DLA_{max}$ ) see Table C406.2.5.4. *Daylight zones* shall meet the criteria in Sections C405.2.4.2 and C405.2.4.3 for primary sidelit *daylight zones*, secondary sidelit *daylight zones*, and toplit *daylight zones*.

GLFA = Project gross lighted floor area, ft<sup>2</sup> or m<sup>2</sup>

$DLA_{TYP}$  = Typical % of *building area* with daylight control (as a fraction) from Table C406.2.5.4:

$EC_{DL5}$  = C406.2.5.4 L04 base energy credits from Section C406.2

(Equation 4-25)

$$EC_{DL} = EC_{DL5} \times 20 \times (DLA_{MAX} - DLA_{TYP})$$

where:

$EC_{DL}$  = The number of credits achieved by this measure.

$EC_{DL5}$  = C406.2.5.4 L04 base energy credits from Section C406.2 Tables C406.2(4), C406.2(6), C406.2(7), and C406.2(8).

$DLA_{TYP}$  = Typical % percent of building floor area with daylight control (as a fraction) from Table C406.2.5.4.

$DLA_{MAX}$  = Maximum percent of building floor area with daylight control that can be counted for compliance with this measure, from Table C406.2.5.4.

**TABLE C406.2.5.4 ADDED DAYLIGHTING PARAMETERS**

Building use type	DLA <sub>TYP</sub>	DLA <sub>MAX</sub>
Group B; <del>Office</del> ≤ 5000 ft <sup>2</sup> (460 m <sup>2</sup> )	10%	20%
Group B; <del>Office</del> > 5000 ft <sup>2</sup> (460 m <sup>2</sup> )	21%	31%
Group M; <del>Retail</del> with ≤ 1000 ft <sup>2</sup> (900 m <sup>2</sup> ) roof area	0%	20%
Group M; <del>Retail</del> with > 1000 ft <sup>2</sup> (900 m <sup>2</sup> ) roof area	60%	80%
Group E; <del>Education</del>	42%	52%
Groups S-1 and S-2; Warehouse	50%	70%
<u>Groups S-1 and S-2; Other than warehouse</u>	<u>NA</u>	<u>NA</u>
<del>Group I-2, R, and other; Medical, hotel, multifamily, dormitory, and other</del>	<del>NA</del>	<del>NA</del>

**Reason:** There are several problems with this credit which are corrected by this proposal:

1. This credit can only be achieved for occupancies where there are values provided for DLATYP and DLAMAX in Table C406.2.5.4 - otherwise the credit cannot be calculated. The relevant tables in C406.2 are amended to indicate that L04 cannot be achieved for those occupancies where DLATYP and DLAMAX are not provided.
2. C406.2.5.4 says that the credit is achieved when “the daylight area of the building is at least 5% greater than a percentage”. Equation 4-23 is added to convert DLABLDG to a percentage so that this comparison can be made.
3. GLFA (gross lighted floor area) is not a readily understood term. It is not used anywhere else in the code, and the word “gross” is unclear. This is revised to LFA (lighted floor area) and given a clear meaning.
4. ECDL is very confusing as the description includes conditional logic. This is broken into two separate equations for clarity.
5. Table C406.2.5.4 is amended to indicate clearly that buildings in Group S-1 and S-2 which are not warehouse cannot obtain the credit.
6. Table C406.2.5.4 is amended to strike the occupancy groups which are currently indicated as “NA”. This does not need to be in C406.2.5.4 when the tables in C406.2 are amended to show that L04 is not available for these occupancies.

**Cost Impact:** The code change proposal will neither increase nor decrease the cost of construction.

No changes in scope or applicability are proposed – revisions are editorial.