

Revise as follows:

SECTION C202 GENERAL DEFINITIONS

LOW SLOPE~~LOW-SLOPED ROOF~~. A roof having a slope less than 2 units vertical in 12 units horizontal (17-percent slope).

Reason: This comment aligns complementary definitions in the IECC and the IBC. The IBC defines “steep slope” as “A roof slope 2 units vertical in 12 units horizontal (17-percent slope) or greater.” Changing the IECC commercial provisions defined term from “low-sloped roof” to “low slope” and adjusting the definition as shown in this comment ensures clarity and correlation between the IECC and IBC.

The phrase “sloped roof” appears in the Commercial 1st Public Comment Draft only once (C402.4 – “Low-sloped roofs directly above cooled conditioned spaces in *Climate Zones 0* through 3 shall comply with one or more of the options in Table C402.4”), and the proposed change of the defined term “low-sloped roof” to “low slope” does not alter understanding of that section.

Comment RED1-182-22 makes correlating changes for the terms “low-sloped roof” and “steep-sloped roof” which were added into the residential 1st Public Comment Draft.