

## Health care committee report for 2015, 2018 and 2021 codes

Changes in black had Healthcare as a proponent

Changes in blue is where Healthcare had a public comment on someone else's change

Changes for 2015 codes					
Code change	Result	Book/Sections	PC?	K-tag	Notes
FS42-12	D	IBC 710.4	yes		Lay in ceiling system
FS47-12	D	IBC 711.9			Elevator lobby separation
FS65-12	D	IBC 713.14.1			Elevator lobby separation
FS113-12	AS	IBC 717.5.5 (IMC 607.5.4)	yes		Smoke barrier exception (not a CHC change)
FS114-12	AMPC1,2	IBC 717.5.5 (IMC 607.5.4)	yes	K372	Smoke damper exception
G1-12	AS	IBC 202			24-hour basis
G54-12	AM	IBC 404.5, 712.1.8		K311	atriums
G68-12	AS	IBC 202, 407.4, 422.3.1			Defend-in-place
G70-12	AS	IBC 202, 407.4.2- 407.4.3.4.2		K256	Care Suites
G71-12 Part 1 & 2	AS/AS	IBC 407.4.2, 407.4.3.3, 407.4.3.4, 407.4.3.5, 407.5, 408.6.1, 408.8.1, 422.3	yes		Distance of travel (not a CHC change)
G76-12	AMPC1	IBC 407.5	yes		40,000 sq.ft.
G77-12	D	IBC 407.9 (New), IFC 604.2.16 (New) [IBC [F] 2702.2.17 (New)]	yes		Emergency power (not a CHC change)
G78-12	AS	IBC 425.1			Hyperbaric
G80-18	AMPC	IBC 407.11, 2702.2.16	yes	K911	Essential electrical power system
G92-12	D	IBC 422.3	yes		40,00 for ambulatory care suites
G128-12	AS	IBC Table 508.4	yes		Pointer to 422.2 for ambulatory care
G130-12	AS	IBC Table 509		K321	Incidental uses
G200-12	D	IBC 3304.8, 3311.3			construction
G219-12	AS	IBC 3404.7, IEBC 403.7			Refuge areas in existing buildings
E25-12	D	IBC/IFC 1006.1.1	yes		Occupancy sensors for lights
E27-12	D	IBC/IFC 1006.2		K281	MOE lighting
E33-12	AS	IBC/IFC 1006.2.1, 1006.3.1			Exit discharge lighting

E67-12	AM	IBC/IFC 1008.1.9.6		K222	Controlled egress doors
E69-12	AMPC1	IBC/IFC 1008.1.9.6	yes	K222	Controlled egress doors
E70-12	AM	IBC/IFC 1008.1.9.7		K222	Delayed egress doors
E72-12	AM	IBC/IFC 1008.1.9.7		K222	Delayed egress doors
E74-12	AMPC	IBC/IFC 1008.1.9.7	yes	K222	Delayed egress doors
E78-12	AM	IBC/IFC 1008.1.9.8		K222	Access controlled egress doors
E81-12	AS	IBC/IFC 1008.1.9.9			Electromagnetic locks
E82-12	AM	IBC/IFC 1008.1.9.9			Electromagnetic locks
E103-12	AMPC	IBC/IFC 1011.6.3	yes	K293	Exit signs power source
E119-18	D	IBC/IFC 1017.3, 1017.5		K232	aisles
E122-12	AS	IBC/IFC 1018.2, Table 1018.2		K232	Corridor width
E179-12	AS	IBC 1104.3, 1107.3, 1107.5.3.1			Maneuvering clearance at patient doors
E199-12	AM	IBC 1109.2			Bariatric toilets
FG3-12 Part 1 and 2	D/D	IFGC 303.3.1, IMC 901.5, 901.6	yes		fireplace
M36-12 Part 1 and 2	AS/AS	IMC 401.2, Table 403.3, 407; IBC 1203.1			Ventilation rates
CCC-12- G7	AS	IBC 407.5.1, 407.9			Gurney or litter vs. stretch
CCC-12- E19	AS	IBC/IFC Table 1018.2			Ambulatory care corridor width
EB25-13	AS	IEBC 803.3			Travel distance in smoke compartments
EB26-13	AMPC2	IEBC 803.6(new)	yes		Fire resistance rating (not a CHC change)
EB33-13	AMPC	IEBC 804.4.1.3	yes		Fire alarm (G257-12)
EB36-13	AM	IEBC 805.3.1.2			Fire escape
EB37-13	AS	IEBC 805.5.2			Transoms (G257-12)
EB39-13	AS	IEBC 805.10			Refuge areas for I-2
EB41-13	AS	IEBC 805.10			Refuge areas or ambulatory care
EB54-13	AS	IEBC 1002.1	yes		COO for hospitals
F14-13	AS	IFC 310.3.1			No smoking sign (NFPA 19.7.4.2)
F26-13	AS	IFC 404.2, 404.3.1, 404.3.2, 405.2, 408.3			Defend in place fire and safety evacuation plans, staff training and drills
F27-13	AS	IFC 404.3.1, 404.3.2, 408.6, 408.6.1, 408.6.2, 408.6.3 (New)			Defend in place fire and safety evacuation plans, staff training and drills

F54-13	AS	IFC 604.1.2 (New) (IBC [F] 2702.1.2), Chapter 80	yes		Generators in a flood zone
F96-13	AS	IFC 611 (New)			Hyperbaric facilities
F104-13	AS	IFC 806.1.1			Trees in ambulatory care
F109-13	AMPC3	IFC 807/IBC 806	yes		Decorative materials (Amy's change)
F111-13	D	IFC (IBC [F] 202); 807.1 (IBC [F] 806.1), 807.4, 807.4.1, 807.4.3.1, 807.4.4, 807.4.4.1, 807.4.5(New)			Decorative materials
F112-13	D	IFC 808.1, 808.2, 5003.8.7.1, 5003.9.10, 5005.1.10, 5704.3.2.1.1, 5705.2.4, Chapter 80	yes		Waste baskets (not a CHC change)
F160-13	AS	IFC 907.2.6 (IBC [F] 907.2.6), 907.5.2.1 (IBC [F] 907.5.2.1), 907.5.2.3 (IBC [F] 907.5.2.3)			Alarm notification
F208-13	AS	IFC 1030.2.1			Security devices (coordination with 2012 changes to locks)
F209-13	AS	IFC 1030.3.1(New)			Aisle and corridor width
F212-13 Part 1 and 2	AMPC3/WP	IFC 1103.1, 1104.1; IEBC 804.2.2.2 (NEW)	yes		Trade offs for partial sprinklers in hospitals
F216-13	AS	IFC 1103.3 (New), 1103.3.1 (New)			Existing elevators
F218-13	AMPC1	IFC 1103.4.1	yes		separation
F220-13	AS	IFC 1103.4.8 (New), 1103.4.9 (New), 603.8.6 (New), 603.8.7 (New)			Waste and line chutes
F225-13	AM	IFC 1103.5.3 (New)			Adding sprinklers
F230-13	AS	IFC 1103.10 (New)			Medical gasses
F233-13	AM	IFC 1104.7			Size of doors
F236-13	AS	IFC 1105 (New)			Incidental uses
F237-13	AS	IFC 1105 (New), 1105.1 (New), 1105.7 (New),			sprinklers

		1105.8 (New); Table 1103.1; 1103.5.2, 1103.7.3			
F238-13	AS	IFC 1105.2 (New), Table 1105.2 (New)			Floor levels
F239-13	AMPC2 &4	IFC 1105.3 (New); 202 (New)			Corridor construction (PC from William Koffel)
F240-13	AM	IFC 1105.4 (New), 1104.5.1, 1104.7, 1104.15, 1104.17.2, Table 1104.17.2, 1104.22			MOE
F241-13	AMPC2	IFC 1105.5 (New)			Smoke compartment (PC from William Koffel)
F242-13	AM	IFC 1105.6 (New), Table 1104.17.2			Travel distance
F243-13	AS	IFC 1105.9 (New)			Electrical system
F291-13	AM	IFC Table 5003.1.1(1) [IBC Table [F] 307.1(1)]			Hazardous materials
F295-13	D	IFC 5003.9, 5003.9.11 (New)	yes		Emergency showers and eyewash stations
F306-13	AS	IFC 5306, 5306.1, 5306.4			Medical gas systems
F308-13	AS	IFC 5306.2.1			Medical gas system room
F309-13	AS	IFC 5306.4			Medical gas system room
F320-13	AS	IFC 5705.5			Alcohol-based hand rub
F344-13	AS	IFC Appendix K(New)			Construction for existing ambulatory care facilities
F348-13	AS	IFC/IBC 907.6.2			Automatic smoke detection (IBC 407.4.3 coord)
F360-13	AMPC1	IFC 908.7 (IBC [F]908.7) through 908.7.7 (IBC [F]908.7.7) (New); 1103.9; 202	yes		Carbon monoxide alarms (not a CHC change)
GG11-14	WP	IGCC 101.3			IGCC not applicable to hospitals
GG43-14	AS	IGCC 202			Asbestos-containing materials (IGCC 805)
GG150-14	AS	IGCC 407.3.2			Bicycle parking
GG233-14	AS	IGCC 804.2			IAQ testing
GG245-14	AM	IGCC 807.1, 807.2.1			Sound transmission
GG249-14	AS	IGCC 807.3.2			Sound levels
GG252-14	D	IGCC 807.5			Sound levels
GG257-14	AM	IGCC 807.6			Sound levels

GG294-14	AM	IGCC 1003.2.2			HVAC
GEW43-14	AM	IGCC 603.2			Energy load type isolation
GEW44-14	AS	IGCC 603.3.1			Gaseous fuels
GEW46-14	AM	IGCC 603.3.2			Liquid fuels
GEW51-14	AM	IGCC 603.5			Energy measurements
GEW59-14	AS	IGCC 604.3			HVAC
GEW90-14	AS	IGCC 606.5.1			Economizer system
GEW94-14	AMPC1	IGCC 606.8	yes		Laboratory exhaust system
GEW98-14	WP	IGCC 607.5, A106.3.2	yes		Group I-2 clarification
GEW99-14	D	IGCC 607.3			Waste water recovery system
GEW111-14	AM	IGCC 607.7			Circulating hot water systems
GEW162-14	AMPC1&2	IGCC 702.18	yes		Autoclaves and sterilizers
GEW175-14	AS	IGCC 703.9.1.1(New)			Overflow alarm supervision
GEW178-14	AM	IGCC 705.1.1			Metering water

Changes for 2018 codes					
Code change	Result	Book/Sections	PC?	K-tag	Notes
FS44-15	AS	IBC 709.5			Smoke barrier openings
FS95-15	AS	IBC 716.5.9.3			Smoke activated doors
FS112-15	D	IBC 717.5.2 (IMC 607.5.2)	Yes		Duct and air transfer opening in fire barriers (not a CHC change)
FS118-12	WP	IBC 717.5.5 (IMC 607.5.4)	Yes		Duct and air transfer opening in smoke barriers (not a CHC change)
FS134-15	AS	IBC Table 803.11			Interior wall and ceiling finishes
G104-15	AS	IBC 407.2.1			Waiting areas
G107-15	AS	IBC 407.5			Smoke barriers
G108-15	WP	IBC 407.5			Smoke barriers
G109-15	D	IBC 407.5	yes		Smoke barriers (not a CHC change)
G111-15	AS	IBC 407.5.2			Smoke compartment MOE
G112-15	AS	IBC 407.6(New), 709.5.1			Automatic doors
G124-15	AS	IBC 202, 422.2, [F] 903.2.2 (IFC 903.2.2)			Ambulatory care separation
G125-15	AS	IBC 422.6 (New), 604.2.1(IBC [F] 2702.2.1) (New)			Electrical in ambulatory care
G148-15	AMPC1	IBC 508.3.1	yes		Occupancy classification
E32-15	AMPC1	IBC 1008.2.2, 1008.3.5;	Yes		Exit discharge lighting

“Copyright©2020 International Code Council, Inc. All rights reserved.”

		(IFC[BE] 1008.2.2, 1008.3.5)			
E45-15	AS	IBC 1009.8; (IFC[BE] 1009.8)			Two way communication
E90-15	AS	IBC 1013.6.3; (IFC[BE] 1013.6.3)			Power source
E106-15	AS	IBC Table 1020.2; (IFC[BE] Table 1020.2)			Corridor width
E117-15	AS	IBC 1025.1; (IFC[BE] 1025.1)			Stair stripes
E124-15	AS	IBC 1026.4.1; (IFC[BE] 1026.4.1)			Refuge area
FG12-15	AMPC1	IFGC 303.3.1 (New)	Yes		fireplace
M12-15	AS	IMC 303.9 (New), 901.5 (New)			fireplace
P34-15	AMPC1	IPC Table 403.1	yes		Description clarification in the fixture table (not an CHC change)
P69-15	AS	IPC 422.1, 609.1, 713.1			Scoping clarification
P70-15	AS	IPC 422.10			Control valve elevations
P71-15	AS	IPC 422.3			Control valve protection
P72-15	AS	IPC 422.4			materials
P73-15	AS	IPC 422.5, 422.9.1			Access to piping
P74-15	D	IPC 422.6, 422.7, 713.2			Flushing rim sinks
P75-15	AM	IPC 422.8			ice
P200-15	AS	IPC 713.4			Vacuum system station
P201-15	AS	IPC 713.5, 713.6, 713.7, 713.7.1, 713.7.2			Medical vacuum system
P207-15	AS	IPC 802.1			Food handling equipment
P208-15	AS	IPC 202, 422, 713, 802.1			sterilizer
S75-16	AS	IBC: 1604.5.			Group clarification to risk category
F10-16	D	IFC: 310.2, 310.3.	yes		smoking
F30-16	AS	IFC: 403.3.4, 405.2.			Fire drills
F73-16	AMPC1	IFC: 603.4, 605.10, 605.10.1 (New).			Space heaters

F76-16	AM	IFC: 604.4, 604.4.1 (New), 604.5, 604.5.1 (New).			Standby power maintained
F82-16	AS	IFC: 605.5.	yes		Extension cord (not a CHC change)
F120-16	AM	IFC: 803.3.			Interior wall finish
F127-16	AM	IFC: 805.2, 805.2.1, 805.2.1.1.			Upholster furniture
F137-16	AM	IFC: 808.1.			wastebaskets
F138-16	AM	IFC: 808.1, 808.1.1 (New), 808.1.2 (New).			wastebaskets
F154-16	AS	IFC 903.2.2 (IBC [F] 903.2.2)	yes		Ambulatory care sprinklers
F198-16	D	IFC: 907.2.2 (IBC: [F] 907.2.2), 907.2.2.1 ([F] 907.2.2.1), K102.4 (New)	yes		Fire alarm boxes
F205-16	D	IFC 907.5.2.1 (IBC [F] 907.5.2.1), 907.5.2.3 (IBC [F] 907.5.2.3)			Audible alarms
F236-16	AS	IFC: 1103.3.1.			elevators
F242-16	AS	IFC: 1104.5.1, 1105.5, 1105.5.1, 1105.5.2.			Emergency power (E90-15)
F244-16	AM	IFC: 1104.7, 1104.7.1 (New), 1104.7.2 (New).			Size of doors
F250-16	AMPC1	IFC 1105.2 (New), 1105.8	yes		Construction requirements
F251-16	AMPC1	IFC: 1105.4.2.	yes		Fire resistance rating
F253-16	AS	IFC: 1105.5.4 (New).		K21	Automatic hold opens
F254-16	AS	IFC: 1105.6.3.			Opening protectives (FS44-15)
F255-16	AS	IFC: 1105.10, 1105.10.1, 1105.10.2.			Electrical system
F357-16	D	IFC: 5003.9, 5003.9.11 (New).			Emergency showers
F367-16	AS	IFC: 5306.1.			Medical gasses
F368-16	AS	IFC: 5306.2, 5306.2.1, 5306.2.2.			Medical gasses
F405-16	AS	IFC: K102.2.2 (New),			Smoke barriers

“Copyright©2020 International Code Council, Inc. All rights reserved.”

		K102.2.3 (New), K102.2.4 (New), K102.2.5 (New), K102.2.6 (New).			
F406-16	AS	IFC: K102.3, K102.3 (New), K102.3.2 (New).			Ambulatory care construction
F407-16	AS	IFC: K102.5 (New), K102.5.1 (New), K102.5.2 (New), K102.5.2.1 (New), K102.5.2.2 (New), K102.5.3 (New), K102.5.4 (New),			Waste linen chutes
CCC7-16	AS	IFC: K104.2.			stretcher

Changes for 2021 codes					
Code change	Result	Book/Sections	PC?	K-tag	Notes
E45-18	AS	IBC: 1010.1.3.2 (New), (IFC[BE] 1010.1.3.2 (New))		K224	Horizontal sliding doors
E52-18	AMPC1	IBC: 1010.1.9.4, (IFC[BE] 1010.1.9.4)	yes	K222	Locks for clinical needs
E55-18	AS	IBC: 1010.1.9.7, (IFC[BE] 1010.1.9.7)		K221	Controlled egress doors in Groups I-1 and I-2.
E57-18	AS	IBC: 1010.1.9.7, (IFC[BE] 1010.1.9.7)		K221	Controlled egress doors in Groups I-1 and I-2.
E59-18	AS	IBC: 1010.1.9.8.1, (IFC[BE] 1010.1.9.8.1)			Delayed egress locks



E61-18	AS	IBC: 1010.1.9.9, (IFC[BE] 1010.1.9.9)			Sensor release of electrically locked egress doors
E92-18	AMPC1	IBC: 1020.5 (IFC[BE] 1020.5)	yes		Air movement in corridors
E123-18	AM	IBC: 1107.5, 1107.5.1, 1107.5.1.1, 1107.5.1.2 (New)			Assisted toileting and bathing – I-1
E124-18	AM	IBC: 1107.5.2, 1107.5.2.1, 1107.5.2.2			Assisted toileting and bathing – nursing homes
E125-18	AM	IBC: 1107.5.4			Assisted toileting and bathing – rehabilitation facilities
E128-18	AS	IBC: 1109.2, 1109.2.2 (New), 1109.2.2.1 (New), 1109.2.2.2 (New), 1109.2.2.2.1 (New), 1109.2.2.2.2 (New), 1109.2.2.2.3 (New), 1109.2.2.3 (New), 1109.2.2.4 (New), 1109.2.2.5 (New), 1109.2.2.6 (New)			Assisted toileting technical
E129-18	AS	IBC: 1109.2, 1109.2.3 (New), 1109.2.3.1 (New), 1109.2.3.2 (New), 1109.2.3.3 (New), 1109.2.3.3.1 (New), 1109.2.3.3.2 (New), 1109.2.3.4 (New), 1109.2.3.5 (New),			Assisted bathing technical

		1109.2.3.6 (New), 1109.2.3.7 (New), 1109.2.3.8 (New), 1109.2.3.9 (New)			
FS38-18	AS	IBC: SECT ION 202, 709.4.1			Smoke compartment
FS39-18	AMPC1	IBC: 710.5, 710.5.3 (New)		K364	Pass through openings in Group I-2 Condition 2.
FS67-18	AS	IBC: 717.5.2 (IMC 607.5.2)			Flex connections
FS86-18	AS	IBC: [F] 806.9 (New)			Combustible lockers
G40-18	AS	IBC: 407.2.6, 407.2.7 (New); IFC: 904.13 (IBC[F] 904.13)			Cooking appliances
G41-18	AS	IBC: 407.2.6			Cooking appliances exceptions
G42-18	AS	IBC: 407.3.1.1 (New), 710.5.2.1		K362	Doors
G43-18	AMPC1	IBC: 407.4.4.1, 407.4.4.3	yes	K256 & K257	Access to corridors
G44-18	AS	IBC: 407.4.4.3		K225	Access to corridors
G46-18	AS	IBC: 407.6.1 (New)		K233	Activation of automatic-closing doors
G55-18	AS	IBC: 420.8, 420.8.1, 420.9 (New); IFC: 904.13 (IBC[F] 904.13)			Cooking appliances
G56-18	AS	IBC: 420.8			Cooking appliances exceptions
G58-18	AS	IBC: 422.1, 422.7 (New)			Cooking appliances
G87-18	D	IBC: 508.3.1.2	yes		separation
G112-18	AS	IBC: 603.1			FRTW
G113-18	AS	IBC: 603.1	yes	K162	Roof construction
F12-18	AS	IFC: 310.2, 310.2.1 (New), 310.3, 310.6			Smoking
F24-18	AS	IFC: 403.3, 403.3.1, 403.3.2, 403.3.3, 403.3.4, 403.8.2			Ambulatory care as subset of Group B
F25-18	AS	IFC: 403.3.1, 403.8.1.1, 403.8.1.1.1, 403.8.2.1, 403.8.3.1			Fire evacuation plans

		(New), 403.10.3.1			
F26-18	AMPC1	IFC: 403.3.2, 403.8.1.1.2, 403.8.2.2, 403.8.3.1 (New), 403.10.3.1.1	yes		Fire safety plan
F27-18	AS	IFC: 403.3.3, 403.8.1.2, 403.8.2.3 (New), 403.8.3.1, 403.8.3.2, 403.8.3.3, 403.10.3.2			Staff training
F28-18	AMPC1	IFC: 403.3.4, 403.8.1.6, 403.8.2.3, 403.10.3.6, 405.1, 405.2 (New)	yes		Fire Drills
F30-18	AS	IFC: 403.8.1.3, 403.10.3.3			Resident training for Group I-1
F31-18	AS	IFC: 403.8.1.4, 403.10.3.4, 405.2, T ABLE 405.2			'employee' vs 'staff'
F32-18	AS	IFC: 403.8.1.4, 403.8.1.5, 403.8.1.7, 403.8.2.3, 403.10.3.5, 405.2, T ABLE 405.2, 405.4, 405.8			Drill timing
F33-18	AS	IFC: 403.8.2.4 (New)			Fire in operating room
F39-18	AM	IFC: 404.2.3, 404.3, 404.4, 404.4.1, 405, 405.1	yes		Lockdown plans
F69-18	AS	IFC: 604.1.1 (New)	yes	K913	Electrical equipment
F73-18	AS	IFC: 604.4.1.1 (New), Chapter 80		K920	UL1363 in ambulatory care
F101-18	AM	IFC: 901.7			Fire protection systems out of service
F122-18 Part 1 & 2	AS/AS	IFC: 903.3.2 (IBC: [F] 903.3.2); IFGC: 303.3.1		K524	fireplaces
F147-18	AS	IFC: 907.5.2.1, 907.5.2.3 (IBC:			Visible alarms exception

		[F]907.5.2.1, [F]907.5.2.3)			
F180-18	AMPC1	IFC: 1031.3.1	yes	K211	Moving wheeled equipment
F188-18	AS	IFC: 1105.5.4.2.2, 1105.5.4.2.4, 1105.5.4.2.5 (New)		K363	doors
F189-18	AS	IFC: 1105.6.1 (New)			Two MOE from each smoke compartment
F192-18	AS	IFC: 1203.4.1, 1203.		K322	Standby power for ambulatory care
F271-18	D	IFC: Chapter 38, SECT ION 3801, 3801.1, SECT ION 3803, 3803.3 (New), 3803.4 (New), 5003.8.3; IBC: 307.1.1, SECT ION 407, 407.12 (New)			Clinic
F282-18	D	IFC: T ABLE 5003.1.1(1), 5003.8.3, 5003.8.3.1, 5003.8.3.2, 5306.2; IBC: [F]T ABLE 307.1(1), [F] 414.2, [F]414.2.1, [F]414.2.2, [F]427.2			Control areas for hazardous materials
F286-18	AS	IFC: 5003.7.4 (New)		K925	Respiratory therapy
F295-18	AS	IFC: 5306.1.1 (New)		K926	Training for medical gases
F297-18 Part 1 & 2	AS/AS	IFC: 5306.5; IPC: 1202.1		K909, K924 and K928	Nonflammable medical gases
M31-18	AS	IMC: 407.1			Mechanical ventilation
M50-18	D	IMC: 505.3	yes		Exhaust ducts
M51-18	D	IMC: 505.3, 505.7 (New)	yes		Domestic cooking systems
M81-18	AS	IMC: SECT ION 920.4 (New)	yes	K523	Unit heaters
P22-18 Part 1 & 2	AS/D	IBC: 1109.2.1.7	Yes/yes		Occupancy indicator (not a CHC change)
P100-18	AS	IPC: 609.2			Water service
EB11-19	AM	IEBC: 302.3.1 (New)		K901, K902,	Codes in healthcare

				K904, K905, K911, K906, K912, K914, K915 and K916	
EB39-19	D	IEBC®: SECTION 306 (New), 306.1 (New), 306.1.1 (New), 306.1.2 (New)	yes		Healthcare in Chapter 3
EB46-19	AS	IEBC®: 406.1.4 (New), 408.3 (New)		K912, and K917	Repaired electrical systems and medical gas systems
EB47-19	AM	IEBC®: 406.1.4 (New), 802.3 (New), 805.4.1.2 (New), 1301.6.4 (New), 1301.6.21 (New), 1301.6.21.1 (New), TABLE 1301.6.21.1 (New), 1301.6.21.1.1 (New), 1301.6.21.2 (New), TABLE 1301.6.21.2 (New), 1301.6.21.2.1 (New), 1301.6.21.3 (New), TABLE 1301.6.21.3 (New), 1301.6.21.3.1 (New), 1301.7 (New), TABLE 1301.7	yes		terminology
EB49-19	AS	IEBC®: 501.3 (New), SECTION 706 (New), 706.1 (New), 807.3 (New), 809.2 (New)		K323, K901, K902, K903, K904, K905, K909, K910,	Electrical

				K913, K915, K916 K923, K925 and K927	
EB59-18	AS	IEBC®: 503.16 (New), 802.3 (New)			Smoke compartment
EB60-19	AS	IEBC®: 503.16 (New), 503.16.1 (New), 503.16.2 (New), 503.16.3 (New), 805.10 (New), 805.10.1 (New), 805.10.1.1 (New), 805.10.1.2 (New), 805.10.1.3 (New), 805.10.2 (New)			Refuge areas
EB61-19	D	IEBC: 503.17 (New), 701.3 (New), 702.7 (New), 703.2 (New), 703.3 (New), 703.4 (New), 704.2 (New), 704.3 (New), 802.2.2 (New), 802.3	yes		Reference to IFC Chapter 11
EB74-19	AS	IEBC: 704.1.1 (New), 805.3 (New)			Corridor width
EB81-19	AS	IEBC: 803.2.2, 803.2.2.2 (New)			Automatic sprinkler system
EB86-19	AS	IEBC®: 803.4.1.2 (New), 803.4.1.3 (New)			Automatic fire alarm system
EB88-19	AS	IEBC®: 805.4.1.2 (New)			suites
EB91-19	AS	IEBC®: 805.6 (New)			Dead end corridor

EB94-19	AMPC1	IEBC: 905.4 (New), 503.17 (New)	yes		Two way communication (not a CHC change)
EB97-19	AS	IEBC®: 1002.1 (New), 1011.1.4 (New)			Change of occupancy
EB98-19	AS	IEBC®: 1002.2 (New)			storage
EB99-19	AS	IEBC®: 1007.1 (New)		K901, K911, and K916	Special occupancies
EB100-19	AS	IEBC®: 1009.5 (New)		K903	Medical gas
CE143-19	AS	IECC: C403.9.6 (New)			Heat recovery for space conditioning