

FLOOR MODIFICATION RED1-69-22-BOYCE-1

Proponent: Amy Boyce, representing Energy Efficient Codes Coalition (amy.boyce@imt.org)

2024 International Energy Conservation Code [RE Project]

Revise as follows:

TABLE R406.5 MAXIMUM ENERGY RATING INDEX

CLIMATE ZONE	ENERGY RATING INDEX NOT INCLUDING OPP	ENERGY RATING INDEX WITH OPP
0-1	51 <u>49</u>	40 <u>33</u>
2	51 <u>49</u>	40 <u>32</u>
3	50 <u>48</u>	40 <u>31</u>
4	53 <u>51</u>	40 <u>38</u>
5	54 <u>52</u>	40 <u>41</u>
6	53 <u>51</u>	40 <u>41</u>
7	52 <u>50</u>	40 <u>41</u>
8	52 <u>50</u>	40 <u>44</u>

FLOOR MODIFICATION # 16

RED1-69-22-BOYCE-1
