

**AD HOC COMMITTEE ON HEALTHCARE
2012 GROUP A CYCLE - IBC, IFGC, IMC, IPC
FINAL ACTION**

Code Change #	Section	AHC Change	Issue	AHC Postion	Final Action
E022	1006.1		Daylight sensors	NP	D
E023	1006.1		Daylight sensors	NP	D
E024	1006.1		Daylight sensors	O	D
E025	1006.1.1	x	Daylight sensors	S	D
E026	1006.2		Illumination	NP	D
E027	1006.2	x	Illumination	S	D
E028	1006.2		Emergency lighting (see E27)	NP	D
E029	1006.2		Auditorium lighting (see E27)	NP	AM
E030	1006.2		Exterior means of egress (see E27)	NP	D
E031	1006.2		Exterior means of egress (see E27)	NP	D
E032	1006.2.1		Reduce to 0.1 ftcdf (see E27)	NP	D
E033	1006.2.1	x	Exterior exit discharge	S	AS
E034	1006.3		Clarification	NP	AM
E067	1008.1.9.6	x	Special locking in Group I-2	S	AM
E068	1008.1.9.6		Special locking in Group I-2	S	D
E069	1008.1.9.6	x	Special locking in Group I-2 - signage	S	AMPC1
E070	1008.1.9.7	x	Delayed egress locks	S	AM
E071	1008.1.9.7		Delayed egress locks	S	D
E072	1008.1.9.7	x	Delayed egress locks - two locks	S	AM
E074	1008.1.9.7	x	Delayed egress locks - signage	S	AMPC1
E075	1008.1.9.7		Delayed egress locks - signage	S	D
E076	1008.1.9.7		Security locking - new	NP	D
E077	1008.1.9.7		Add I-1 and I-4 to locks	S	AS
E078	1008.1.9.8	x	Access controlled egress doors	S	AM
E079	1008.1.9.8		Access controlled egress doors	NP	D
E080	1008.1.9.8		Access controlled egress doors	NP	AS
E081	1008.1.9.9	x	Electromagnetic locks	S	AS
E082	1008.1.9.9	x	Electromagnetic locks	S	AM
E083	1008.1.9.9		Access controlled egress doors	S	D
E103	1011.6.3	x	Exit signs	S	AMPC
E118	1017.3		Aisles	S	AS
E119	1017.3	x	Aisles	S	D
E120	1017.5		Aisles	S	D
E122	1018.2	x	Bed movement	S	AS
E123	1018.2		Corridors within a suite	O	WP
E125	1018.6		Openness to corridor	O	D
E149	1024.5		Lights for photoluminescent strips on stairs	O	AM
E151	1025.1		Horizontal exits	S	WP
E152	1025.4		Refuge areas	O	WP
E179	1104.3	x	Hospital doors	S	AS
E199	1109.2	x	Bariatric units	S	AM
FG002	303.3		Fuel burning appliances Combustion air permitted from the inside	O	D
FG003	303.3.1	x	Fireplaces	S	D
FS037	709.4		Smoke barrier continuity	S	AMPC
FS038	709.4		Smoke barrier continuity	NP	D
FS039	709.4		Smoke barrier continuity	NP	D

**AD HOC COMMITTEE ON HEALTHCARE
2012 GROUP A CYCLE - IBC, IFGC, IMC, IPC
FINAL ACTION**

Code Change #	Section	AHC Change	Issue	AHC Postion	Final Action
FS040	709.5		Corridor doors in Group I-2 and ACFs	S	AS
FS041	710		Format 710	NP	D
FS042	710.4	x	Smoke partition continuity	S	D
FS047	711.9	x	Smoke barrier	S	D
FS048	711.9		Smoke barriers	S	D
FS049	711.9		Smoke barriers	S	D
FS050	711		Floor and roof assemblies	NP	AM
FS056	713.3		Chutes - NFPA 82	O	WP
FS065	713.14.1	x	Elevators lobbies not in hospitals	S	D
FS066	713.4.1		Required elevator lobbies at 420 ft.	NP	D
FS068	713.14.1		Elevator lobbies for Group I-1 Condition 2	NP	AS
FS070	713.14.1		Elevator open to exterior	NP	AMPC2
FS072	714.2		Certified Firestop Contractors - Group I-2	O	WP
FS078	715.2		Certified FR Joint Contractors - Group I-2	O	WP
FS113	717.5.5		Smoke barrier	NP	D
FS114	717.5.5	x	Smoke damper exception	S	AMPC1 AMPC2
G001	202	x	24 hour basis	S	AS
G031	308		Group I-1, Condition 1 & 2;	S	AS
G032	308		Group I-5 hospitals & Group I-2 to custodial care	O	D
G033	308		Lock-up facilities	NP	WP
G035	308.3		Assisted living as Group I-2	NP	D
G037	308.5		Lock-up facility	O	D
G042	311.1.2		Accessory storage	NP	AS
G054	404.6	x	Atrium enclosure in I-2	S	AM
G055	404.6		Add enclosure in Group I-1, Condition 2	NP	AM
G058	404.9		Exit access travel distance in atrium	NP	AMPC
G065	407.2.5		Cooking facilities in nursing homes	NP	AMPC
G067	407.3		Corridor walls in suites	O	D
G068	407.4	x	Defend in place	S	AS
G069	407.4.1		Suite should have access to a corridor.	O	D
G070	407.4.2	x	Suite size (see G/5)	S	AS
G071 Part 1	407		Terms inside suites	O	AS
G072	407.4.3.5		Doors in suites	O	AS
G074	407.4.3.2		Separation of suites	O	AS
G075	407.4.3.6.1		Care suites not containing sleeping rooms	S	AS
G076	407.6	x	Smoke compartment size	S	AMPC1 AMPC2
G077	407.9		EM Power in Group I-2 Hosp & Nursing homes	S	D
G078	407.1	x	Hyperbaric facilities	S	AS
G079	407.11		Range hoods in hospital	NP	D

**AD HOC COMMITTEE ON HEALTHCARE
2012 GROUP A CYCLE - IBC, IFGC, IMC, IPC
FINAL ACTION**

Code Change #	Section	AHC Change	Issue	AHC Postion	Final Action
G080	407.11	x	Electrical requirements (see G77)	S	AMPC
G092	422.8	x	Smoke compartment increase - ambulatory care (See G76)	S	D
G093	422.8		Type V Const H/A allowances	O	D
G096	425		Storm shelters	O	D
G097	425		Decontamination room	O	D
G128	508.4	x	Pointer for ambulatory care	S	AS
G130	509	x	Inciendtal use tables	S	AS
G174	3007.7		Elevator lobbies	NP	D
G200	3304.8	x	Defend in place	S	D
G219	3404.7	x	Refuge area when doing alterations	S	AS
G244	3412		Alternative compliance	S	AMPC
G257	308	x	Group I-2, Condition 1 and 2	S	AM
M010	303.1		Fuel fired appliance	NP	AS
M035	309.2		Heating	O	D
M036	401.2	x	Hospital ventilation rates	S	AS
M076	505.1		Cooking hoods	NP	AS
P028	403.1		Hand wash sinks in exam and procedure rooms	NP	D
P069	422.11		Wastewater leak detection in hospitals	O	D
P171	713.12		Wastewater leak detection in hospitals	O	D
P231	403.1		Water temperature in ambulatory care	NP	D
S338	App. L		Building resiliance (New)	NP	D