

Table 1008.1.9			
Door Hardware and Lock Systems (Note 1)			
Occupancy	Occupant Load	Door Hardware or Lock Systems Required	Door Hardware or Lock Systems Permitted
A	<50	Classified as Group B Occupancy. See 303.1.1	
	>= 50 & <= 300	Panic hardware or fire exit hardware complying with 1008.1.10. Note exception in 1008.1.10 for main exterior door.	At main exterior (egress) door only, key-operated locking devices from the egress side complying with 1008.1.9.3, Item 2. Other lock systems permitted, see note(s): 3 & 4.
	>300	Panic hardware or fire exit hardware complying with 1008.1.10.	Other lock systems permitted, see note(s): 3 & 4.
<i>Places of Religious Worship</i>	Any		At main exterior (egress) door only, key-operated locking devices from the egress side complying with 1008.1.9.3, Item 2.
B	<=50		At main exterior (egress) door only, key-operated locking devices from the egress side complying with 1008.1.9.3, Item 2. Manually operated bolts are permitted on the inactive leaf of a pair of doors, complying with 1008.1.9.4, Item 3. Other lock systems permitted, see note(s): 2, 3, 4.
	>50		At main exterior (egress) door only, key-operated locking devices from the egress side complying with 1008.1.9.3, Item 2. Manually operated bolts are permitted on the inactive leaf of a pair of doors, complying with 1008.1.9.4, Item 4. Other lock systems permitted, see note(s): 2, 3, 4.
E	<50		Other lock systems permitted, see note(s): 3, 4.
	>= 50	Panic hardware or fire exit hardware complying with 1008.1.10.	Other lock systems permitted, see note(s): 3, 4.
F	<=50		At main exterior (egress) door only, key-operated locking devices from the egress side complying with 1008.1.9.3, Item 2. Manually operated bolts are permitted on the inactive leaf of a pair of doors, complying with 1008.1.9.4, Item 3. Other lock systems permitted, see note(s): 2.
	>50	Panic hardware or fire exit hardware complying with 1008.1.10.	At main exterior (egress) door only, key-operated locking devices from the egress side complying with 1008.1.9.3, Item 2. Manually operated bolts are permitted on the inactive leaf of a pair of doors, complying with 1008.1.9.4, Item 4. Other lock systems permitted, see note(s): 2.
H	Any	Panic hardware or fire exit hardware complying with 1008.1.10.	
I-1 I-4 I-5	Any		Other lock systems permitted, see note(s): 2.
I-2	Any		For a pair of doors serving patient care rooms, self latching bolts are permitted on the inactive leaf not needed for egress, complying with 1008.1.9.3, Item 5. Special locking arrangements complying with 1009.1.9.6. Other lock systems permitted, see note(s): 2 & 3.
I-3	Any		Locking arrangements within correctional facilities complying with 1008.1.9.10.
M	Any		At main exterior (egress) door only, key-operated locking devices from the egress side complying with 1008.1.9.3, Item 2. Other lock systems permitted, see note(s): 2, 3, 4.
R-1 R-2	Any		Doors not required for egress may have manually operated bolts, complying with 1008.1.9.4, Item 1. Other lock systems permitted, see note(s): 2, 3, 4.
R-3	Any		Doors not required for egress may have manually operated bolts, complying with 1008.1.9.4, Item 1. Other lock systems permitted, see note(s): 2.
R-4		Closet doors shall be openable from the inside. Bathroom doors shall be unlockable from the ingress side. Comply with 1008.1.9.5.1.	Other lock systems permitted, see note(s): 2
S	<50		At main exterior (egress) door only, key-operated locking devices from the egress side complying with 1008.1.9.3, Item 2. Manually operated bolts are permitted on the inactive leaf of a pair of doors, complying with 1008.1.9.4, Item 3. Other lock systems permitted, see note(s): 2
	>= 50		At main exterior (egress) door only, key-operated locking devices from the egress side complying with 1008.1.9.3, Item 2. Manually operated bolts are permitted on the inactive leaf of a pair of doors, complying with 1008.1.9.4, Item 4. Other lock systems permitted, see note(s): 2
Equipment Rooms			Manually operated bolts are permitted on the inactive leaf of a pair of doors, complying with 1008.1.9.4, Item 2.
Notes			
1	The unlatching of any door or leaf shall not require more than one operation. See exceptions in 1008.1.9.5		
2	Delayed egress locks complying with 1008.1.9.7.		
3	Access-controlled egress doors, complying with 1008.1.9.8		
4	Electromagnetically locked egress doors, complying with 1008.1.9.9.		