

FLOOR MODIFICATION

RB4-22-NUGENT-1

Proponent: Mike Nugent, representing Building Code Action Committee (bcac@iccsafe.org)

2021 International Residential Code

R101.2 Scope. The provisions of this code shall apply to the construction, *alteration*, movement, enlargement, replacement, *repair*, equipment, use and occupancy, location, removal and demolition of detached one- and two-family dwellings and *townhouses* not more than three stories above *grade plane* in height with a separate means of egress and their *accessory structures* not more than three stories above *grade plane* in height.

Exception: The following uses shall be permitted to be constructed in accordance with the code where located within a dwelling unit that is provided with an automatic sprinkler system complying with Section P2904:

1. Live/work units complying with the requirements of Section 508.5 of the International Building Code.
2. Owner-occupied *lodging houses* with five or fewer guestrooms.
3. A care facility with five or fewer persons receiving custodial care.
4. A care facility with five or fewer persons receiving medical care .
5. A day care facility for five or fewer persons receiving care .