

FLOOR MODIFICATION

RB45-22-NUGENT-1

Proponent: Mike Nugent, representing Building Code Action Committee (bcac@iccsafe.org)

2021 International Residential Code

R802.4.1 Rafter size. Rafters shall be sized based on the rafter spans in Tables R802.4.1(1) through R802.4.1(8). Rafter spans shall be measured along the horizontal projection of the rafter. For other grades and species and for other loading conditions, refer to the AWC STJR. ~~Joist~~ Rafter splices shall comply with Section R301.9.

R802.5 Ceiling joists. Ceiling joists shall be continuous across the structure or securely joined where they meet over interior partitions in accordance with Section R802.5.2.1. Ceiling joists shall be fastened to the top plate in accordance with Table R602.3(1). ~~Rafter~~ Joist splices shall comply with Section R301.9.

FLOOR MODIFICATION # 2860

RB45-22-NUGENT-1
