

IFC

Code Change # 1

1027.22 Exit path markings. In addition to the requirements in 1011.6, exit path markings shall comply with 1027.22.1.

1027.22.1 Obstacles. Obstacles at or below 6 feet 6 inches (1981 mm) in height and projecting more than 4 inches (102 mm) into the egress path shall be outlined with stripes not less than 1 inch (25 mm) in width comprised of a pattern of alternating equal bands of material and black with the alternating bands not more than 2 inches (51 mm) thick and angled at 45 degrees.