

CTC Meeting # 22
December 1 – 2, 2011
Care facilities SG report (2 of 2)
Coordination of CTC/Ad Hoc Healthcare Proposals

FIRE SAFETY WORK GROUP

Issue 1: DECORATIONS ON WALLS

- *CTC Care Facilities co-proponent*
- *Need to coordinate with Fire Code Action Committee*
- *CTC adding proposal for Group I-1 and I-2 patient rooms to have 30% (#3)*

*IBC [F] 806.1(IFC 807.1) General requirements
In group I-1 and I-2, 20% of decorative materials on any wall*

Issue 1A: Natural Cut Trees in AHCF's

- *CTC Care Facilities not participating*

*IFC 806.1, 806.1.1 and 806.3
Not allow cut Christmas trees in Ambulatory Care*

Issue 3: INTERCOMMUNICATION BETWEEN FLOOR OPENINGS

- *CTC Care facilities co-proponent*
- *Extend proposal to all Group I-2*
- *Code change from CTC to add Group I-1, Condition 2 (#13)*

*IBC 404.5 and 712.1.8
Do not allow a two story opening in Group I-2 hospitals*

Issue 4: SMOKE DAMPER EFFECTIVENESS & SHUTDOWN PARAMETERS

CTC Care Facilities does not want to expand to nursing homes or participate

*IBC 717.5.5
Dampers in smoke barriers*

Issue 5: CORRIDOR WALLS/SMOKE PARTITIONS AND 5A.CEILING SMOKE RESISTANT MEMBRANE

- *CTC Care Facilities does not want to participate*

*IBC 710.4 Continuity
Lay in ceiling to resist smoke*

Issue 6: VENTILATION RATES Brooks

- *CTC Care Facilities co-proponent*
- *Include Group I-2 nursing homes*
- *Eliminate term 'convalescent homes'*
- *Adhoc committee asked about deletion of 'convalescent home' from Group I-1 (#14)*

IMC 401.2; Table 403.3; Section 407(new)

Ventilation in Group I-2 to comply with ASHRAE 170

Issue 7: COOKING FACILITIES IN BREAK ROOMS – APPLICATION OF COMMERCIAL EXHAUST PROVISIONS

- See CTC care proposal #2 – IMC 505 and 507
- The Adhoc Health committee will support the domestic hood code change proposal from the CTC Care Facilities Committee

Issue 9 FIRE ALARMS - AUDIBLE AND VISIBLE

- *CTC Care Facilities will not participate*

*IBC [F] 907.2.6/IFC 907.2.6 and IBC [F] 907.5.2.1/IFC 907.5.2.1
Alarms in critical care of Group I-2 hospitals*

Issue 11: HAZARDOUS MATERIAL LOCATIONS (Incidental use areas)

- *CTC Care Facilities co-proponent*
- *Include Group I-2 nursing homes*

Table 509 Incidental Uses
Add spaces for Group I-2

Issue 12 ALCOHOL-BASED HAND RUB DISPENSERS IN PATIENT ROOMS

- *CTC Care Facilities would support as co-proponent*

IFC 5705.5 Alcohol-based hand rubs classified as Class I or II liquids

Issue 14 Fire Safety and Evacuation Plans

- *CTC Care Facilities co-proponent*
- *Include Group I-2 nursing homes*
- *CTC Care will add change for Group I-1 (#11)*

*IFC 404; 408.3(new); 408.6
Fire and safety evacuation plans for Ambulatory Care and Group I-2*

GENERAL WORK GROUP

PROPOSAL 1 – Topic 2 Defend in Place

- *CTC Care Facilities co-proponent*
- *Include Group I-2 nursing homes*
- *Have decided to not include Group I-1*

Defend in place definition; 407.4 and 422.3.1 (new)

PROPOSAL 2 – Topic 3 Smoke Compartment Size

- *CTC Care Facilities would not want for Group I-2 nursing homes – not participating*

407.5 and 422.3; increase smoke compartment for Group I-2 hospital only

PROPOSAL 4 – Topic 4 Use of facilities during renovations

- *CTC Care Facilities would not want to participate*
- *Would add nursing homes as a public comment if successful*

IFC 3304.8(new) and 3311.3(new)

Fire watch and corridor width for Group I-2 hospitals being altered

PROPOSAL 5 - Topic 9 Mixed Use and accessory occupancy provisions.

- *CTC Care Facilities co-proponent*
- *Would like this expanded to Group I-2 nursing homes)*

IBC 1018.2 – Corridor width in Group I-2 where there is no bed movement

PROPOSAL 6 – Topic 9 Mixed Use and accessory occupancy provisions.

- *CTC Care Facilities would not participate*

Table 508.4

Footnote for Ambulatory Care

PROPOSAL 7 - Topic 12 Existing standard references and terminology related to health care

- *CTC Care Facilities will not participate*

IBC [F]2702.1.1 Generators to comply with flood standard when applicable

PROPOSAL 8 – Topic 13

- *CTC Care Facilities co-proponent*

407.5.1; 407.9; Table 1018.2;

Change to term ‘stretcher’

MEANS OF EGRESS WORK GROUP

#MOE1 -

- *CTC Care Facilities will not participate*

407.5.3; 711.9

Delete hidden lobby

#MOE2 –

- *CTC Care Facilities will not participate*
- *Agree that this should apply to all Group I-2*
- *Make correlative change to add Group I-1, Condition 2 (#7)*

IBC 713.14.1 no elevator lobbies in Group I-2

#MOE3

- *CTC Care Facilities co-proponent*

1017 Aisles refer to Section 1018.2 rather than 36” minimum.

#MOE4

- *CTC Care Facilities as co-proponent*
- *Group I-2 only since I-1 does not have 96" corridors required*

IFC 1030

Wheeled equipment in corridors

#MOE5

- *CTC Care Facilities be co-proponents*

1008.1.9.7 Delayed egress cleanup

#MOE6

- *CTC Care Facilities be co-proponents*

1008.1.9.7 Delayed egress allowance for 2 locks with 30 seconds total

#MOE7

- *CTC Care Facilities not participate*
- *Put together change add Group I-1 and I-4 to where this is allowed (#8)*

1008.1.9.8 Access controlled egress doors cleanup

#MOE8

- *CTC Care Facilities co-proponent;*
- *Separate change for Group I-1, Condition 2 (#9)*

1008.1.9.6 Special locking arrangements in Group I-2

#MOE12

- *CTC Care Facilities not participate since they typically do not use suites*
- *Leave all Group I-2*

Care Suite definition; 407.4.2; 407.4.3; 407.8; 907.2.6.2

Suites enlarged and clarified

#MOE9

- *CTC Care Facilities not participate since only applicable to hospitals*

1104.3; 1107.3, 1107.5.3.1

Coordination with ADA for hospital doors

#MOE10 –

- *CTC Care Facilities not participate but agree*

1109.2 – exception for bathrooms designed for bariatric patients

MOE#11 -Option #2: Change definition:

- *CTC Care Facilities co-proponent*
- *CTC Care including this in their main change*

24 hour care definition