



ICC 400-202X edition Second Committee Action Report

**For Committee Action taken on public
comment received on June 7, 2021 for
meeting held on June 10, 2021
held via Webex**

Chapter 3 GENERAL REQUIREMENTS

ICC 400 Section 305.3.1.1

Proponent: Loren Ross, American Wood Council

Revise as follows:

305.3.1.1 U-Factor. The U-Factor (U_w) of the opaque log wall assembly shall be selected from Table 305.3.1.1 to meet the Mass Wall U-Factor requirements of Table R402.1.2 or C402.1.3 4 of the IECC as applicable.

Reason: The current language only requires a wall to be selected from Table 305.3.1.1 and not have a specific maximum U-factor. This change would clarify the intent that the U-factor path of 305.3.1.1 be in compliance with the mass wall requirements of the IECC.

Committee Action: Approved as modified

Committee Reason: Typo on the table designation.